



**BOLTON
& MENK**

Real People. Real Solutions.

418 S Dawson Street
Raleigh, NC 27596

Ph: (919) 719-1800
Bolton-Menk.com

November 8th, 2024

TO ALL PROSPECTIVE BIDDERS

Mill Bridge Amphitheater

Bid Date: December 10th, 2024
Time 10:00 AM

Bid Submittal: Town of Rolesville
Town Hall
502 Southtown Circle
Rolesville, NC 27571

ADDENDUM #3:

This Addendum, issued prior to receipt of bids, shall and does hereby become part of the Contract Documents for the referenced Project. All Prime Contractors shall be responsible for ensuring that their Subcontractors are properly apprised of the contents of this Addendum. All information contained in this Addendum shall take precedence over any conflicting information in the original Drawings and Specifications, dated September 3, 2024.

PLAN & SPECIFICATION REVISIONS:

1. NA

RESPONSES TO QUESTIONS RECEIVED FROM BIDDERS:

1. The last addendum was listed as Addendum No. 2. What was Addendum No. 1?
 - a. Further clarification was added to the Ad for Bid on accessing the plans and specs and that had to be uploaded as an addendum, so it was counted as Addendum 1. The ad for bid and all addendum are available on the Town's website or the State's eVP site.
2. Can you send the CAD drawings that were part of Addendum No. 2 in a PDF format?
 - a. The drawings that were sent as CAD files are in the plans as the site plan (C2.00) and the grading plan (C4.00) for PDF form. There are no changes to these sheets from the bid plans.
3. Is the seating made up of small segmental walls? No section through the seating or notes referencing the seating are found.
 - a. The amphitheater walls will be segmental block walls, as identified on the plans as the "Belgard Diamond Pro Retaining Wall System." The heights for the walls have been provided on the grading plans. These notes are on Sheet C2.00 in the plans.

ATTACHMENTS:

1. NA

Best regards,
BOLTON & MENK, INC.,

Jacqueline Thompson, PE
Project Engineer
Jacqueline.Thompson@bolton-menk.com