SDP-24-06 – ROLESVILLE CROSSING AMENITY CENTER – V2 Submittal review cycle

START DATE: SEPTEMBER **2024** DUE DATE: _10-07-24_ TRC/STAFF Comments issued on: __10/04/2024_

Review Group / Staff		Comments	Cleared Comments
Planning & Zoning – Planning Staff	 Continue to Continue to NEW – She the UDO S language of NEW – Cov 'construct' 	to Provide a Written Response to ALL comments. to Add revision dates to all submittal materials. to Cloud/bubble all changes in the plan set. eet L5.00 – The Note: add specific language like "based on the adjacent Land Uses to Lot OS 1006, Section 14.6.5. does not require (perimeter) Landscape Bufferyards be installed. All the 'elective' can remain as is. over Sheet/All Sheets – Title – This plan set is a Site Development Plan; while a constructable (or the from') plan, please refrain from using the term of 'construction drawing'. Revise to state Site ment Plan. Thank you.	
Engineering - Brian Laux / Jacque Thompson		(1.) See PDF of Written memo comments dated 10-02-2024, with 9 comments, and; (2.) See PDF of Mark-up comments with 13 entries/comments.	
Wake County Watershed Management - Janet Boyer		V2 – No comments received; see V1 comment; what is status? V1 - SEC/SWF permits required from Wake County.	
COR Public Utilities - Tim Beasley		 Add a note on the Utility Plan stating "Where discharge to the storm sewer is not possible and a swimming pool is connected to the sanitary sewer system for the purposes of draining or flushing the pool/fountain or backwashing the filters, the drainage system shall be equipped with a pump or flow restructure so that the discharge rate to the sanitary sewer does not exceed 50 GPM." The CORWLE should just encompass the water meter, not the BFP. Add a note for size, make and model number for the BFP with the statement "or Raleigh Approved Equal". 	
Wake County Fire / EMS - Brittany Hocutt		No further Comments.	✓
NCDOT – Jacob Nicholson		No comments expected.	NA
Parks & Recreation - Eddie Henderson		There are no comments.	✓