

**CID-24-03 – Wallbrook Lot 8 – V3 Submittal review cycle**

START DATE: <b>JULY 2024</b>	DUE DATE: <u>  07-17-24  </u>	TRC/STAFF Comments issued on: <u>  07/17/2024  </u>
------------------------------	-------------------------------	---

Review Group / Staff	Comments	Cleared Comments
Planning & Zoning – Planning Staff	<ol style="list-style-type: none"> <li>1. Continue to - Provide a Written Response to ALL comments.</li> <li>2. Continue to - Add revision dates to all submittal materials.</li> </ol>	
Engineering - Brian Laux / Jacque Thompson	<p>IF Wake County approves their SEC Permit, only this comment remains:</p> <ul style="list-style-type: none"> <li>• Please confirm the LOD acreage has been updated throughout the plan, including Sheets C0.1, C1.1, C1.2. Version 2 of the plans appeared to have the LOD change but the acreage was not updated.</li> </ul> <p>Note: Engineering will not need to see another review, Town Planning can confirm the above.</p>	
Wake County Watershed Management - Janet Boyer	Permit SEC-121766-2024 <b>Disapproval</b> dated 07-15-2024	
<i>COR Public Utilities - Tim Beasley</i>	<i>No comments.</i>	