



Real People. Real Solutions.

418 South Dawson Street
Raleigh, NC 27601

Phone: (919) 719-1800
Bolton-Menk.com

MEMORANDUM

Date: March 5, 2025
To: Michael Elabarger
From: Jacqueline Thompson, PE
Subject: Pearce Farm
CID 24-08, 2nd Submittal
Town of Rolesville, NC

This memo summarizes the review of 2nd submittal of construction drawings package submitted by McAdams Engineering dated 02/03/2024 (received 02/06/2025).

SL 2.0:

1. Since this plan set is for Phases 1 through 3 only, the lighting plan only needs to include those phases as well.
2. Please add a professional seal to all lighting plans; lighting plans require a professional seal.

SL 2.1:

3. It appears that light poles are in the planting strip between the curb and the sidewalk. All light poles should be located behind the sidewalk. Please revise all lighting plan sheets.
4. D1 light poles are difficult to see on the plans. Consider making the symbol larger throughout the lighting plans to make it easier to identify their locations.