



**American Engineering**  
4020 Westchase Boulevard, Suite 450  
Raleigh, NC 27607  
919.469.1101  
www.american-ea.com

April 1, 2025

Ms. Jacqueline Thompson  
Bolten & Menk  
418 S Dawson Street  
Raleigh, NC 27601

Subject: **Tucker Wilking Preliminary Plat**  
Preliminary Submittal, PSP 23-01; AE Project ID: R210017

Dear Ms. Thompson,

We are in receipt of your comment letter dated January 30, 2024 for the above referenced Preliminary Subdivision Plan. The following have been uploaded for your review and approval:

- Referenced Preliminary Subdivision Plan set

Specifically, we have modified the plan in response to comments in your letter as noted below.

#### **SHEET C2.2**

1. *2024 NCDOT ramp details are now active. Consider implementing for CDs.*  
Noted.

#### **SHEET 6.0**

2. *Please clarify the material for the 10' sidepath.*
  - a. *This comment also applies to Sheet C6.1.*  
Material of sidepath has been added to plans.
3. *Label ramps and ramp material as concrete.*  
Label has been added to ramps and material called out.
4. *Label existing 5' concrete sidewalk that the proposed 10' asphalt path will transiting to.*  
Label has been added.

#### **SHEET 6.1**

5. *Existing FES and CB labels are shown while structures are not shown. Please show structures or delete label from this page.*  
Labels have been removed from this sheet.

We are confident the revisions have addressed your comments. Please don't hesitate to contact me at [jklein@american-ea.com](mailto:jklein@american-ea.com) if you have any questions or require additional information.

Regards,

A handwritten signature in blue ink, appearing to read "Jakob P. Klein".

Jakob P. Klein, P.E.  
Raleigh Office Manager  
American Engineering Associates – Southeast, PA, Inc.