## CID-23-04 - Wallbrook-Virginia Water Drive Extension - 4th Submittal review cycle

START DATE: MAY 2024 DUE DATE: \_\_06/10/24\_ TRC/STAFF Comments issued on: \_\_06/09 /2024\_\_

Review Group / Staff		Comments	Cleared Comments
Planning & Zoning – 2. Co Planning Staf 2. Co 3. To 4. Se		whitinue to Provide a Written Response to all the Comments with next submittal. NOTED witinue to Revise the dates of the Plan set for the next submittal. with planning and Engineering have no further comments. The Comments from other signature entities — CORPUD has comments, and the last status from Wake punty Watershed was Disapproval.	
Wake County Watershed Management - Janet Boyer  V4 – no new comment or status was received.  V3 - See PDF of SEC / SWF permits Disapproval from Wake County, dated 04-05-2024.			
COR Public Utilities Tim Beasley	water and 2) The depth will not b 3) Please ad occurs in a minimu 4) Once the	dese email me the public water and sewer permit applications. Once received, I will provide the assigned public ter and sewer permit numbers that should be added to all of the applicable permit blocks. depth of the existing 16" critical water main needs to be field verified prior to CD approval. Sanitary design not be approved until this has been done. as add a note (C3.1) stating the following, "Raleigh Water staff may need to be onsite while any construction that in the vicinity of the critical water transmission main. Please email	

## CORPUD RESPONSES

- 1. APPLICATIONS WILL BE SENT
- 2. NOTE ADDED TO C3.1 TO FIELD VERIFY LOCATION PRIOR TO ANY UTILITY WORK
- 3. NOTE ADDED TO C3.1
- 4. NOTED. WE WILL CONTACT YOU REGARDING FEES